





FACULTEIT INGENIEURSWETENSCHAPPEN Vakgroep TEXTIELKUNDE Technologiepark 907, B-9052 Gent (Zwijnaarde) T +32 9 264 57 35 - F +32 9 264 58 46 http://textiles.UGent.be textiles@UGent.be

## Test certificate Nr LTA010111

#### 28/01/2011

#### Classification of Flat, woven, knitted or needled textile floor coverings without pile EN 15114

#### **1 Definition of the flooring**

*1.1 Producer* Le Tissage d'Arcade

*1.2 Flooring* Product group 2TEC2

### 2 Tests

The means of control are described in the certification contract LTA010111.

#### **<u>3 Classification</u>**

Referring to the means of control and the test results, the before mentioned flooring can be classified as follows:

	Commercial 33 Heavy	
Certificate valid until: 2010 Didier Van Daele Head of floorcoverings/fire	(Cert	







FACULTEIT INGENIEURSWETENSCHAPPEN Vakgroep TEXTIELKUNDE Technologiepark 907, B-9052 Gent (Zwijnaarde) T +32 9 264 57 35 - F +32 9 264 58 46 http://textiles.UGent.be textiles@UGent.be

## Annex to TEST CERTIFICATE N° LTA010111


28/01/2011

### Classification of Flat, woven, knitted or needled textile floor coverings without pile EN 15114

Flooring: product group 2TEC2

## Additional characteristics

1. Vetterman (ISO 10361)	after 5000 cycles	after 22000 cycles	Classification
	≥4	≥ 3.5	33
2. Lisson (EN 1963) :		< 30 g/m <sup>2</sup>	
3. Castor Chair (EN 985):		continuous use	
4. Walking test (ISO 6356):		< 2kV	
5. Insulation from impact no	oise (EN ISO 140-8)	: $\Delta L_w = 12 \text{ dB}$	
6. Acoustical absorption (El	N ISO 354) :	$\alpha_{\rm w} = 0.05 \; ()$	
7. Fraying behaviour (EN 18	814):	Pass	
8. Slip (EN 13893):		≥ 0.3	





# Test certificate Nr TDA060221/01

# Fire classification of construction products and building elements - Part 1: Classification using test data from reaction to fire tests (EN 13501-1:2007+A1 (2009))

## **1** Definition of the flooring

1.1 Producer Tissage d'Arcade sa

#### 1.2 Flooring

Product group: 2TEC2

## 2 Tests

The means of control are described in the certification contract TDA060221

## 3 Classification

Referring to the means of control and the test results, the before mentioned flooring can be classified as follows:

glued on a non-combustible underground

B<sub>fl</sub> s1

Certificate valid until 2016-06-30

ir Petra Wittevrongel product certifier

Date: 20 106/2011